



IEC 62305-4

Edition 1.0 2006-01

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

---

**Protection against lightning –  
Part 4: Electrical and electronic systems within structures**

**Protection contre la foudre –  
Partie 4: Réseaux de puissance et de communication dans les structures**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

PRICE CODE  
CODE PRIX **XD**

## CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	9
2 Normative references .....	9
3 Terms and definitions .....	10
4 Design and installation of a LEMP protection measures system (LPMS).....	23
4.1 Design of an LPMS.....	16
4.2 Lightning protection zones (LPZ).....	16
4.3 Basic protection measures in an LPMS .....	20
5 Earthing and bonding .....	20
5.1 Earth termination system.....	21
5.2 Bonding network.....	23
5.3 Bonding bars .....	28
5.4 Bonding at the boundary of an LPZ .....	28
5.5 Material and dimensions of bonding components.....	28
6 Magnetic shielding and line routing.....	29
6.1 Spatial shielding.....	29
6.2 Shielding of internal lines .....	29
6.3 Routing of internal lines.....	29
6.4 Shielding of external lines .....	30
6.5 Material and dimensions of magnetic shields.....	30
7 Coordinated SPD protection .....	30
8 Management of an LPMS .....	31
8.1 LPMS management plan .....	31
8.2 Inspection of an LPMS .....	33
8.3 Maintenance.....	34
Annex A (informative) Basics for evaluation of electromagnetic environment in a LPZ .....	35
Annex B (informative) Implementation of LEMP protection measures for electronic systems in existing structures .....	61
Annex C (informative) SPD coordination .....	78
Annex D (informative) Selection and installation of a coordinated SPD protection .....	96
Bibliography.....	101
Figure 1 – General principle for the division into different LPZ .....	13
Figure 2 – Protection against LEMP – Examples of possible LEMP protection measures systems (LPMS) .....	15
Figure 3 – Examples for interconnected LPZ.....	18
Figure 4 – Examples for extended lightning protection zones.....	19
Figure 5 – Example of a three-dimensional earthing system consisting of the bonding network interconnected with the earth termination system.....	21
Figure 6 – Meshed earth termination system of a plant .....	22

Figure 7 – Utilization of reinforcing rods of a structure for equipotential bonding .....	24
Figure 8 – Equipotential bonding in a structure with steel reinforcement .....	25
Figure 9 – Integration of electronic systems into the bonding network .....	26
Figure 10 – Combinations of integration methods of electronic systems into the bonding network .....	27
Figure A.1 – LEMP situation due to lightning flash .....	37
Figure A.2 – Simulation of the rise of magnetic field by damped oscillations .....	39
Figure A.3 – Large volume shield built by metal reinforcement and metal frames .....	40
Figure A.4 – Volume for electrical and electronic systems inside an inner LPZ n.....	41
Figure A.5 – Reducing induction effects by line routing and shielding measures .....	43
Figure A.6 – Example of an LPMS for an office building .....	44
Figure A.7 – Evaluation of the magnetic field values in case of a direct lightning flash .....	46
Figure A.8 – Evaluation of the magnetic field values in case of a nearby lightning flash .....	48
Figure A.9 – Distance $s_a$ depending on rolling sphere radius and structure dimensions .....	51
Figure A.10 – Types of grid-like large volume shields .....	53
Figure A.11 – Magnetic field strength $H_{1/\max}$ inside a grid-like shield Type 1.....	54
Figure A.12 – Magnetic field strength $H_{1/\max}$ inside a grid-like shield Type 1.....	54
Figure A.13 – Low-level test to evaluate the magnetic field inside a shielded structure .....	56
Figure A.14 – Voltages and currents induced into a loop built by lines .....	57
Figure B.1 – Upgrading of LEMP protection measures and electromagnetic compatibility in existing structures .....	63
Figure B.2 – Possibilities to establish LPZs in existing structures.....	69
Figure B.3 – Reduction of loop area using shielded cables close to a metal plate .....	71
Figure B.4 – Example of a metal plate for additional shielding .....	72
Figure B.5 – Protection of aerials and other external equipment .....	74
Figure B.6 – Inherent shielding provided by bonded ladders and pipes .....	75
Figure B.7 – Ideal positions for lines on a mast (cross-section of steel lattice mast).....	76
Figure C.1 – Example for the application of SPD in power distribution systems.....	79
Figure C.2 – Basic model for energy coordination of SPD .....	81
Figure C.3 – Combination of two voltage-limiting type SPDs .....	82
Figure C.4 – Example with two voltage-limiting type MOV 1 and MOV 2.....	84
Figure C.5 – Combination of voltage-switching type spark gap and voltage-limiting type MOV .....	85
Figure C.6 – Example with voltage-switching type spark gap and voltage-limiting type MOV.....	86
Figure C.7 – Determination of decoupling inductance for 10/350 $\mu$ s and 0,1kA/ $\mu$ s surges ....	87
Figure C.8 – Example with spark gap and MOV for a 10/350 $\mu$ s surge .....	89

Figure C.9 – Example with spark gap and MOV for 0,1kA/μs surge .....	91
Figure C.10 – Coordination variant I – Voltage-limiting type SPD .....	92
Figure C.11 – Coordination variant II – Voltage-limiting type SPD .....	93
Figure C.12 – Coordination variant III – Voltage-switching type SPD and voltage-limiting type SPD .....	93
Figure C.13 – Coordination variant IV – Several SPDs in one element .....	94
Figure C.14 – Coordination according to the “let through energy” method .....	94
Figure D.1 – Surge voltage between live conductor and bonding bar .....	97

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**PROTECTION AGAINST LIGHTNING –****Part 4: Electrical and electronic systems within structures**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62305-4 has been prepared by IEC technical committee 81: Lightning protection.

The IEC 62305 series (Parts 1 to 5), is produced in accordance with the New Publications Plan, approved by National Committees (81/171/RQ (2001-06-29)), which restructures in a more simple and rational form and updates the publications of the IEC 61024 series, IEC 61312 series and the IEC 61663 series.

The text of this first edition of IEC 62305-4 is compiled from and replaces

- IEC 61312-1, first edition (1995);
- IEC 61312-2, first edition (1998);
- IEC 61312-3, first edition (2000);
- IEC 61312-4, first edition (1998).

The text of this standard is based on the following documents:

FDIS	Report on voting
81/265/FDIS	81/270/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted, as close as possible, in accordance with the ISO/IEC Directives, Part 2.

IEC 62305 consists of the following parts, under the general title *Protection against lightning*:

Part 1: General principles

Part 2: Risk management

Part 3: Physical damage to structures and life hazard

Part 4: Electrical and electronic systems within structures

Part 5: Services<sup>1</sup>

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

---

<sup>1</sup> To be published.

## INTRODUCTION

Lightning as a source of harm is a very high-energy phenomenon. Lightning flashes release many hundreds of mega-joules of energy. When compared with the milli-joules of energy that may be sufficient to cause damage to sensitive electronic equipment in electrical and electronic systems within a structure, it is clear that additional protection measures will be necessary to protect some of this equipment.

The need for this International Standard has arisen due to the increasing cost of failures of electrical and electronic systems, caused by electromagnetic effects of lightning. Of particular importance are electronic systems used in data processing and storage as well as process control and safety for plants of considerable capital cost, size and complexity (for which plant outages are very undesirable for cost and safety reasons).

Lightning can cause different types of damage in a structure, as defined in IEC 62305-2:

- D1 injuries to living beings due to touch and step voltages;
- D2 physical damage due to mechanical, thermal, chemical and explosive effects;
- D3 failures of electrical and electronic systems due to electromagnetic effects.

IEC 62305-3 deals with the protection measures to reduce the risk of physical damage and life hazard, but does not cover the protection of electrical and electronic systems.

This Part 4 of IEC 62305 therefore provides information on protection measures to reduce the risk of permanent failures of electrical and electronic systems within structures.

Permanent failure of electrical and electronic systems can be caused by the lightning electromagnetic impulse (LEMP) via:

- a) conducted and induced surges transmitted to apparatus via connecting wiring;
- b) the effects of radiated electromagnetic fields directly into apparatus itself.

Surges to the structure can be generated externally or internally:

- surges external to the structure are created by lightning flashes striking incoming lines or the nearby ground, and are transmitted to electrical and electronic systems via these lines;
- surges internal to the structure are created by lightning flashes striking the structure or the nearby ground.

The coupling can arise from different mechanisms:

- resistive coupling (e.g. the earth impedance of the earth termination system or the cable shield resistance);
- magnetic field coupling (e.g. caused by wiring loops in the electrical and electronic system or by inductance of bonding conductors);
- electric field coupling (e.g. caused by rod antenna reception).

NOTE The effects of electric field coupling are generally very small when compared to the magnetic field coupling and can be disregarded.

Radiated electromagnetic fields can be generated via

- the direct lightning current flowing in the lightning channel,
- the partial lightning current flowing in conductors (e.g. in the down conductors of an external LPS according to IEC 62305-3 or in an external spatial shield according to this standard).

## PROTECTION AGAINST LIGHTNING –

### Part 4: Electrical and electronic systems within structures

#### 1 Scope

This part of IEC 62305 provides information for the design, installation, inspection, maintenance and testing of a LEMP protection measures system (LPMS) for electrical and electronic systems within a structure, able to reduce the risk of permanent failures due to lightning electromagnetic impulse.

This standard does not cover protection against electromagnetic interference due to lightning, which may cause malfunctioning of electronic systems. However, the information reported in Annex A can also be used to evaluate such disturbances. Protection measures against electromagnetic interference are covered in IEC 60364-4-44 and in the IEC 61000 series [1]<sup>2</sup>.

This standard provides guidelines for cooperation between the designer of the electrical and electronic system, and the designer of the protection measures, in an attempt to achieve optimum protection effectiveness.

This standard does not deal with detailed design of the electrical and electronic systems themselves.

#### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60364-4-44:2001, *Electrical installations of buildings – Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances*

IEC 60364-5-53:2001, *Electrical installations of building – Part 5-53: Selection and erection of electrical equipment– Isolation, switching and control*

IEC 60664-1:2002, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 61000-4-5:1995, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

IEC 61000-4-9:1993, *Electromagnetic compatibility (EMC) – Part 4-9: Testing and measurement techniques – Pulse magnetic field immunity test*

IEC 61000-4-10:1993, *Electromagnetic compatibility (EMC) – Part 4-10: Testing and measurement techniques – Damped oscillatory magnetic field immunity test*

---

<sup>2</sup> Figures in square brackets refer to the bibliography.

IEC 61000-5-2:1997, *Electromagnetic compatibility (EMC) – Part 5: Installation and mitigation guidelines – Section 2: Earthing and cabling*

IEC 61643-1:1998, *Surge protective devices connected to low-voltage power distribution systems – Part 1: Performance requirements and testing methods*

IEC 61643-12:2002, *Low-voltage surge protective devices – Part 12: Surge protective devices connected to low-voltage power distribution systems – Selection and application principles*

IEC 61643-21:2000, *Low voltage surge protective devices – Part 21: Surge protective devices connected to telecommunications and signalling networks – Performance requirements and testing methods*

IEC 61643-22:2004, *Low voltage surge protective devices – Part 22: Surge protective devices connected to telecommunications and signalling networks – Part 22: Selection and application principles*

IEC 62305-1, *Protection against lightning. Part 1: General principles*

IEC 62305-2, *Protection against lightning. Part 2: Risk management*

IEC 62305-3, *Protection against lightning. Part 3: Physical damage to structures and life hazard*

ITU-T Recommendation K.20:2003, *Resistibility of telecommunication equipment installed in a telecommunications centre to overvoltages and overcurrents*

ITU-T Recommendation K.21:2003, *Resistibility of telecommunication equipment installed in customer premises to overvoltages and overcurrent*